




NAME: _____ DATE: _____
(Please Print)

RESIDENTIAL PRACTICE EXAM

**THE USE OF THE 2020 N.E.C. BOOK IS PERMITTED
(Formulas and Worksheets on back pages)**

The following questions are worth one point each.



1. Based on the drawing above, what is the minimum number of exterior outlets required, assuming no balconies, decks or porches?

- A. 1
- B. 2
- C. 3
- D. 4

210.52(E)(1)

Answer

B

2. Based on the drawing above, what is the minimum size service for this dwelling.

- A. 100 Amp, 120 Volt
- B. 200 Amp, 120 Volt
- C. 100 Amp, 240 Volt
- D. 200 Amp, 240 Volt

230.79(C)

Answer

C


3. Rigid nonmetallic PVC conduit is installed underground, in the back lawn, as a raceway between a dwelling and a shed. Three 10 AWG Type THW insulated conductors and a bare 10 AWG equipment ground are pulled into the raceway. The circuit is protected by a 30 amp GFCI circuit breaker. What is the minimum burial depth permitted for the raceway?

- A. 150 mm
- B. 12 inches
- C. 450 mm
- D. 24 inches

Table 300.5
Column 3

Answer

C



4. Based on the drawing above, what is the *minimum* size ungrounded (hot) service wire required?

- A. 1 Copper
- B. 3 Copper
- C. 4 Copper
- D. 4/0 Aluminum

310.12(A)
Table 310.12

Answer A

5. Based on the drawing above, what *minimum* size main grounding electrode conductor is required to be run to a Concrete Encased Electrode (UFER Ground)?

- A. #6 THHN Copper
- B. #4 THWN Copper
- C. #2 Bare Copper
- D. #1/0 Bare Aluminum

250.66 (B)

Answer B

6. What is the minimum number of 15 amp lighting circuits required for a 3500 square foot residence?

- A. 5
- B. 6
- C. 8
- D. 12

220.14(J)
 $3500 \times 3 = 10500 \text{ VA}$
 $10500 \div 120 \text{ v} = 87.5 \text{ A}$
 $87.5 \text{ A} \div 15 \text{ A} = \text{at least } 5.83$. Will
require at least 6 circuits

Answer B

7. What is the demand factor permitted for a household with a 11 kW range?

- A. 8,000 watts
- B. 9,000 watts
- C. 11,000 watts
- D. 20,000 watts

Table 220.55, Column C,
1 Appliance, 8kW

Answer A

8. A continuous load, such as an EV charger, is one in which maximum current is expected to continue for how many hours?

- A. At least one
- B. At least three
- C. No more than five
- D. All night long

Article 100 Definitions
"Continuous Load"

Answer B

9. What is the minimum volume of a 4"x4"x1-1/2" electrical box which has no volume markings on it?

- A. 254 cubic centimeters
- B. 18 cubic inches
- C. 24 cubic inches
- D. 344 cubic centimeters

Table 314.16(A)


Answer D

10. What is the minimum size of Rigid Steel conduit permitted for three 2/0 AWG type THW compact stranded aluminum conductors used for a 150 amp dwelling service?

- A. 1-1/2 inch
- B. 1-1/4 inch
- C. 1 inch
- D. 2 inch

Annex C
Table C.1(A)

Answer A



11. Based on the drawing above, and assuming Flexible Metal Conduit (FMC), what is the *maximum* length of section “C”?

- A. 6 inches
- B. 1 foot
- C. 24 inches
- D. 3 feet

348.30(A)

Answer B

12. Based on the drawing above, and assuming Electrical Metallic Tubing (EMT), what is the *maximum* length of section “B”?

- A. 3 meters
- B. 8 feet
- C. 900 millimeters
- D. 3 feet

358.30(A)

Answer A

13. Based on the drawing above, and assuming 1” Rigid Metal Conduit (RMC), what is the radius of the bend when using a Full Shoe Bender?

- A. 101.6 mm.
- B. 5 inches.
- C. 146.05 mm.
- D. 8 inches.

344.24
Chapter 9, Table 2

Answer C

14. If an EMT conduit containing 3 THHN conductors is run in an attic with a possible temperature of 120°F, what is the correction factor required for determining ampacity?

- A. 82 %
- B. 88 %
- C. 90 %
- D. 91 %

310.15(B)(1)

Answer A

15. A residential dwelling with a 3200 square foot area excluding porches, garage, and unfinished spaces requires a general lighting load of not less than _____ VA before application of any demand factors.

- A. 3600 VA
- B. 4500 VA
- C. 10,000 VA
- D. 9600 VA

220.14(J)

Answer D

16. Arc-fault circuit-interrupter protection for receptacle outlets shall be provided for all dwelling unit

- A. Garages
- B. Bathrooms
- C. Living rooms
- D. Furnaces
- E. All of the above
- F. None of the above

210.12(A)

Answer C

17. What must a room have in order to be considered a bathroom?.

- A. Toilet
- B. Tub
- C. Shower
- D. Sink
- E. Urinal

100 Definitions
"Bathroom"

Answer D


18. If watts and voltage are known, how would current be calculated?

- A. Voltage ÷ Wattage
- B. Voltage² ÷ Resistance
- C. Watts ÷ Voltage
- D. Voltage² ÷ Wattage

Power Law → $P = I \times E$
Solve for I
 $I = P \div V$, or Watts ÷ Volts

Answer C

19. Draw a schematic diagram showing one light being controlled by 4 switches.



The following question is worth 3 points.

20. A *three-story*, single-family dwelling measures 20' x 30' on the outside of the building. Using the Standard Calculation method, what is the computed minimum size 120/240 volt service assuming a dishwasher rated at 5 amps, a garbage disposal rated at 1/3 hp (use table 430.248), a 10.5kW Range, a 3.5 kW, 240 volt water heater and a 240 volt, 10 amp air conditioner.

- A. 60 Amp
- B. 100 Amp
- C. 150 Amp
- D. 200 Amp

Show your work

20'x30'x3 (stories) =1800 sq.ft.	
1800x3VA	=5400VA
Small Appliance 1500x2	=3000VA
Laundry 1500x1	=1500VA
Total	= 9900VA


First 3000VA	=3000VA
9900-3000=6900VAx35%	=2415VA
Total	=5415VA

D.W. =(5 amps x 120 volts)	= 600VA
Disp. (Table 430.248) (7.2 amps x 120 volts)	=864VA
Water Heater	=3500VA
Total	=4964VA

Range (Table 220.55, Column C)	= 8000VA
Air Cond. (240 volts x 10 amps)	= 2400VA
25% of largest motor (A/C)	=600VA
Total	=11000VA
	+5415VA
	+4964VA
	=21379VA

21379VA ÷ 240 volts = **89 Amps**
Minimum 100 Amp service required.

Answer B



21. Based on the drawing above, what is the minimum number of receptacle outlets required to serve the countertop?

- A. 4
- B. 5
- C. 7
- D. 8

210.52(C)(1)

Answer B

22. Based on the drawing above, the outlets that serve the countertop requires:

- A. GFCI protection
- B. AFCI protection
- C. WR (weather-resistant) rated receptacles
- D. TR (tamper-resistant) receptacles
- E. A,B and D above
- F. All the above
- G. None of the above

210.8(A)(6)
210.12(A)
406.12


Answer E

23. What **minimum** size metal device box is required for eight 12 AWG Type THWN copper conductors and 2 duplex receptacle outlets?

- A. 3 in. x 2 in. x 3-1/2 in.
- B. 4 in. x 4 in. x 1-1/2 in.
- C. 4 in. x 4 in. x 2-1/8 in.
- D. 3 in. x 2 in. x 2-1/4 in.

314.16(B)
8- #12 =8 cond. @ 2.25 cubic inches
314.16(4)
2- outlets =4 cond. @ 2.25 cubic inches
12x2.25=27 cu in
Table 314.16(A)→

Answer C



24. Based on the drawing above, what is the *maximum* horizontal distance allowed between the inside wall of the pool and the required receptacle?

- A. 5 ft
- B. 6 ft
- C. 10 ft
- D. 20 ft

680.22(A)(1)

Answer D

25. Based on the drawing above, what is the minimum requirement for the conductor that bonds the pool, light, deck, motor, ladder, etc.?

- A. 8 AWG solid copper
- B. 8 AWG stranded copper
- C. 8 AWG solid aluminum
- D. 8 AWG stranded aluminum
- E. A&B above

680.26(B)


Answer A

26. Dwelling unit receptacles shall be located so that no point along the floor line is more than _____, measured horizontally, from an outlet in that space.

- A. 12 ft.
- B. 2 ft.
- C. 6 ft.
- D. 10 ft.

210.52(A)(1)

Answer C



The following questions are based on the drawing above.

27. Which switches may be closed for **only** light 1 to illuminate?

- A. S1, S2, S3
- B. S4, S5, S6
- C. S1, S2, S3, S6
- D. S1, S2, S4
- E. C and D above
- F. All of the above

A-L2 will light. B-Neither will light.
C-Both will light. D-L1 will light.

Answer D

28. Which switches may be closed for **only** light 2 to illuminate?

- A. S1, S4, S6
- B. S1, S2, S3
- C. S2, S4, S5, S6
- D. S1, S2, S3, S4, S5, S6
- E. None of the above
- F. All of the above

A-Both will light. B-L2 will light.
C-Both will light. D-Both will light.

Answer B

29. Which switches may be closed for **both** lights to illuminate?

- A. S1, S2, S4
- B. S1, S2, S5, S6
- C. S2, S3, S6
- D. S1, S5
- E. All of the above
- F. None of the above

A-L1 will light. B-Neither will light.
C-Both will light. D-Neither will light.

Answer C

30. What happens if all the switches are closed?

- A. Only light 1 illuminates
- B. Only light 2 illuminates
- C. Both lights illuminate
- D. A short circuit is created

All switches closed will illuminate both lights (through several paths).

Answer C

Electrical Exam Formulas

- 1) $P = I \times E$
- 2) $E = I \times R$
- 3) $P = I \times E \times (PF)$
- 4) $VD = (2 \times K \times D \times I) / CM$
- 5) $VD (3 \text{ Phase}) = (1.73 \times K \times D \times I) / CM$

P= Power in watts

I=Current in amps

E=Voltage in volts

R=Resistance in ohms

VD=Voltage drop in volts


PF=Power factor

D=Distance (one way) in feet


CM=Circular mils of wire (NEC Ch. 9, Table 8)

K=Resistance of a circular mil-foot (Approx. 12.9 for Cu, 21.2 for Al)

HP=746 Watts



1/8" Scale





Dwelling Unit Load Calculations

Standard Calculation

Question 20

1. General Lighting Loads (220.12)

20x30x3=1800 sq. ft. x 3 VA = 5400 VA

Minimum number of circuits
 _____ VA ÷ 120 Volts = _____ Amps
 _____ Amps ÷ 15 or 20 amp ckts. = _____ ckts

2. Small Appliance Branch Circuits (220.52(B))

2 x 1500 VA = 3000 VA

3. Laundry Equipment Load (220.52(A))

1 x 1500 VA = 1500 VA

4. Total General Lighting, Small Appliance and Laundry Circuit Load (1. + 2. + 3.)

9,900 VA

5. Application of Demand Factors (Table 220.42)

5a. First 3,000 Volt-Amperes at 100% 3000 VA

5b. Line 4 minus 3000 = 6900

5c. If Line 5b > 117,000, then 117,000 x 35% = _____ VA

5d. If Line 5b < 117,000, then Line 5b x 35% = 2415 VA

5e. If line 5b > 117,000, then Line 4 minus 120,000 = _____ x 25% = _____ VA

5f. Net general lighting and small appliance load (5a+5c+5d+5e) 5415 VA

6. Appliance load—Dwelling Unit(s) (220.53)

See table 430.248 for full-load current if no nameplate rating.

Appliance	Nameplate-VA (Watts)
Dishwasher	600
Disposal	864
Water Heater	3500

6a. Total (If less than four)

6a. Total (If four or more) _____ x 75% = 4964 VA

7. Add Other Loads (Range, Dryer, Heat, A/C)

(Use largest of coincident loads)

7a. Range load (Table 220.55) 8000 VA

7b. Dryer load (Table 220.54) _____ VA

7c. Air Conditioner 2400 VA

7d. _____ VA

7e. 25% of Largest Motor from sec 6. or 7.(220.50) Air Conditioner (VA) x 25% = 600 VA

7f. Total Calculated Load (Add 5f. thru 7e.) 21379 VA

Minimum size of ungrounded (Hot) service conductors

(Line 7f. above) VA ÷ 240 Volts = 89 Amps

8. Minimum Size of Grounded (Neutral) Service Entrance Conductors

8a. Lighting and small appliance load (5f.) + 120 Volt appliance loads (6a.) = _____ VA

8b. Range load at 70% = _____ VA

8c. Dryer load larger of 5000 or nameplate Volt-amperes at 70% = _____ VA

8d. Total for grounded service-entrance conductor _____ VA

(Line 8d. above) VA ÷ 240 Volts = _____ Amps