

Schedule


Symbol	Label	Quantity	Manufacturer	Catalog Number	Description	Number Lamps	Lumens Per Lamp	Light Loss Factor	Wattage
○	A	4	Sternberg Lighting	1130LED-24L40T5-MDL018	1130LED, Ripon Series Acorn, new LEDil optic, T5, Acrylic Acorn	1	11986	0.93	115.1
⊕	B	3	Sternberg Lighting	1130LED-24L40T3-MDL018	1130LED, Ripon Series Acorn, new LEDil optic, T3, Acrylic Acorn	1	11388	0.93	115.2

Statistics

Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
1. NEW PARKING AREA	✕	1.3 fc	5.7 fc	0.1 fc	57.0:1	13.0:1
2. ALL CALC POINTS	+	0.3 fc	5.7 fc	0.0 fc	N/A	N/A

NOTES:

- CALCULATION POINT WORK PLANE: GRADE LEVEL
- FIXTURE MOUNTING HEIGHT: 14'-0" ABOVE GRADE



**This document contains confidential and proprietary information of KSA Lighting & Controls. This document may only be used by or for the benefit of KSA Lighting & Controls representatives and customers. This lighting layout is not a professional engineering drawing and is provided for informational purposes only, without warranty as to accuracy, completeness, reliability or otherwise. KSA Lighting & Controls is not responsible for specifying the light fixtures or illumination requirements for any specific project, nor is it responsible for meeting municipal or building code requirements. It is the obligation of the end-user to consult with a professional engineering advisor to determine whether this lighting layout meets the applicable project requirements for lighting system performance, safety, suitability and effectiveness for use in a particular application. Field verification is recommended when calculations are based on end-user or customer-provided information. End-user environment and application (including, but not limited to, voltage variation and dirt accumulation) can cause actual field performance to differ from the calculated photometric performance represented in this lighting layout. In no event will KSA Lighting & Controls be responsible for any loss resulting from any use of this drawing.

Schedule


Symbol	Label	Quantity	Manufacturer	Catalog Number	Description	Number Lamps	Lumens Per Lamp	Light Loss Factor	Wattage
⊙	A	4	Sternberg Lighting	1130LED-24L40T5-MDL018	1130LED, Ripon Series Acorn, new LEDil optic, T5, Acrylic Acorn	1	11986	0.93	115.1
⊕	B	3	Sternberg Lighting	1130LED-24L40T3-MDL018	1130LED, Ripon Series Acorn, new LEDil optic, T3, Acrylic Acorn	1	11388	0.93	115.2

Statistics

Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
1. NEW PARKING AREA	⊗	1.3 fc	5.7 fc	0.1 fc	57.0:1	13.0:1
2. ALL CALC POINTS	⊕	0.3 fc	5.7 fc	0.0 fc	N/A	N/A

NOTES:

1. CALCULATION POINT WORK PLANE: GRADE LEVEL
2. FIXTURE MOUNTING HEIGHT: 14'-0" ABOVE GRADE



**This document contains confidential and proprietary information of KSA Lighting & Controls. This document may only be used by or for the benefit of KSA Lighting & Controls representatives and customers. This lighting layout is not a professional engineering drawing and is provided for informational purposes only, without warranty as to accuracy, completeness, reliability or otherwise. KSA Lighting & Controls is not responsible for specifying the light fixtures or illumination requirements for any specific project, nor is it responsible for meeting municipal or building code requirements. It is the obligation of the end-user to consult with a professional engineering advisor to determine whether this lighting layout meets the applicable project requirements for lighting system performance, safety, suitability and effectiveness for use in a particular application. Field verification is recommended when calculations are based on end-user or customer-provided information. End-user environment and application (including, but not limited to, voltage variation and dirt accumulation) can cause actual field performance to differ from the calculated photometric performance represented in this lighting layout. In no event will KSA Lighting & Controls be responsible for any loss resulting from any use of this drawing.